



NOTES:

- FOR DUAL CONNECTIONS SHOWN ON PLANS APPLY U-BRANCH MUELLER AND MUELLER 300 BALL STRAIGHT METER VALVES FOR 3/4" METERS
- NO COMPONENTS SUBSTITUTIONS UNLESS AS AUTHORIZED BY CITY OF MONT BELVIEU.
- WATER LINES SHALL CARRY NSF EMBLEM.
- REFER TO OTHER DETAILS FOR COMPACTED SAND OR STABILIZED BACKFILL.
- REFER TO WATER SERVICE LINE CONNECTIONS LONG AND SHORT SIDE DETAILS FOR MORE INFORMATION.
- BEND HOPE PIPE AT 48" MIN RADIUS OR AT MANUFACTURERS RECOMMENDATION. NO KINKING.
- LINE TESTING AND CHLORINATION SHALL INCLUDE FILLED SERVICE LATERALS.

STEEL OPTION:

- 1 - 0" BELL FLANGE ADAPTER
- 1 - 0" SLIP-ON FLANGE
- 1 - 0" X 45° STEEL BEND (IF REQ'D)

Mont Belvieu TEXAS

Waterline Standard Details

Scale: NTS

DWG No: 100 - 02

SHEET 2 OF 3